BRE Global

Notified Body No. 0832

BRE Global Limited Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX Telephone: +44 (0)1923 664100 Fax: +44 (0)1923 664603 Email: <u>enquiries@breglobal.com</u> Web: <u>www.breglobal.com</u>

Certificate of constancy of performance,

0832-CPR-F1617

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

7251 Analogue Addressable Photoelectric Laser Smoke Detector

(For full product details and conditions of use refer to appendix)

Produced by or for

Life Safety Distribution GmbH, System Sensor Europe

Javastrasse 2 CH-8604 Hegnau Switzerland

and produced in the manufacturing plant(s)

Ademco de Juarez S, de R.L., de C.V.

Av. Rosa Maria Y. Fuentes No. 7070 C.P. 32437, Parque Industrial Fuentes Ciudad Juárez Chihuahua Mexico

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-7:2000 + A1:2002 + A2:2006 - Smoke detectors - Point detectors

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 01 September 2016 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Valliga

P Halligan, Certification Manager On behalf of BRE Global Limited Date of issue: 01 September 2016 Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email <u>enquiries@breglobal.com</u>.

Notified Body No. 0832

BRE Global

BRE Global Limited Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX Telephone: +44 (0)1923 664100 Fax: +44 (0)1923 664603 Email: <u>enquiries@breglobal.com</u> Web: <u>www.breglobal.com</u>

Appendix to Certificate of constancy of performance 0832-CPR- F1617

Bases:

B501	Standard Analogue Detector Base
B501AP	Intelligent Detector Base
B501DG	Deep Analogue Detector Base
B524IEFT-1	Short Circuit Isolator Detector Base

Sensitivity Settings:

Sensitivity settings 7-8 inclusive

Walligar.

P Halligan, Certification Manager On behalf of BRE Global Limited Date of issue: 01 September 2016 Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email <u>enquiries@breglobal.com</u>.