

Certificate of Constancy of Performance



0359-CPR-00176

Appendix to Certificate of Constancy of Performance 0359-CPR-00176

The details and conditions of use for the Mini Monitor Input / Output Module, placed on the market under the name or trade mark of:

Life Safety Distribution GmbH (Trading as System Sensor Europe)

Javastrasse 2, 8604 HEGNAU, Switzerland

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN54-18:2005+AC:2007

Part Number	Manufacturing Location	Description
M501MEA	JUARMX.01	Mini Monitor Input / Output Module

Conditions of use:

Suitable for indoor applications

Alternative part numbers and labelling:

Original Part Number	Alternative Part Number	Distributed By
M501MEA	NFX-MM1M MI-MM3E-S2 TC809EA1035	Notifier by Honeywell Morley IAS Fire Systems by Honeywell Honeywell Control Systems

General Notes:

1. Evaluated under Intertek project number 100770420, 101672421, 102042803 and 102435609.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00176
Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex,
CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Appendix to Certificate of Constancy of Performance 0359-CPR-00176 (continued)

Table of performance for EN54-18:2005+AC:2007		
Harmonised technical specification		
Essential characteristics	Performance	Clauses
Response delay (response time)	Pass	5.2
Performance under fire conditions	Pass	5.1.4
Operational reliability	Pass	5.1.4
Durability of operational reliability temperature resistance	Pass	5.3, 5.4
Durability of operational reliability; vibration resistance	Pass	5.8 to 5.11
Durability of operational reliability; humidity resistance	Pass	5.5, 5.6
Durability of operational reliability; corrosion resistance	Pass	5.7
Durability of operational reliability; electrical stability	Pass	5.2, 5.12
<p><i>Note:</i></p> <p><i>For details relating to performance conditions and associated clauses which are applicable to the product(s) under test, refer to Intertek test reports 100770420LHD-007, 101672421LHD-001 and 102042803LHD-001.</i></p>		