

Certificate of Product Approval

Certificate Number: 199aa-(cl-2)

Issue: 02

Honeywell Products & Solutions Sàrl (Trading as System Sensor Europe)

Zone d'Activitiés La Pièce 16
CH-1180 Rolle
Switzerland



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Multi-Criteria Detectors with Short Circuit Isolator
22051TLEI
22051TEI
(refer to Appendix for details)

Standards

EN 54-5:2000 + A1:2002
EN 54-7:2000 + A1:2002 + A2:2006
EN 54-17:2005
CEA 4021:2003

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

21 September 2020

Date of Issue

26 July 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 199aa-(cl-2)

Issue: 02

Honeywell Products & Solutions Sàrl (Trading as System Sensor Europe)

Certified Product	Description	LPCB Ref.No.
22051TLEI	Analogue Addressable Photo-Thermal-IR Multi-Criteria Smoke Sensor with Short Circuit Isolator (B501AP and B524HTR Bases) Note: 1. Certified at the following settings: - Alarm levels 1 to 5 (Multi-Criteria): EN 54-5:2000 Class A1R, EN 54-7:2000 & CEA 4021:2003 - Alarm level 6 (Heat only mode): EN 54-5:2000 Class A1R	199aa/01
22051TEI	Analogue Addressable Photo-Thermal Multi-Criteria Smoke Sensor with Short Circuit Isolator (B501AP and B524HTR Bases) Note: 1. Certified at the following settings: - Alarm levels 1 to 5 (Multi-Criteria): EN 54-5:2000 Class A1R, EN 54-7:2000 & CEA 4021:2003 - Alarm level 6 (Heat only mode): EN 54-5:2000 Class A1R	199aa/02

Bases

B501AP Intelligent Sensor Base
B524HTR Heater Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

21 September 2020

Date of Issue

26 July 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.


